

# NOTIFICATION OF TEST RESULTS

Issued to: Wago-Kontakttechnik GmbH & Co. KG  
Hansastraße 27, 32423 Minden/Westfalen, Germany

For the product: Splicing wire connectors

Trade name: WAGO

Type/Model: 221

Manufactured by: Wago-Kontakttechnik GmbH & Co. KG  
Hansastraße 27, 32423 Minden/Westfalen, Germany

Ratings: 450 V, 32 A, 4 mm<sup>2</sup>

Additional information: This NTR replaces NTR NL-7698 issued on 27 August 2018, due to the fact that new types 221-2401 and 221-2411 and factory locations are added  
See Annex for factory locations  
CTF Stage 3

**A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard**  
EN 60998-1:2004, EN 60998-2-2:2004

**As shown in the Test Report**  
2245563.50


This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body, which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

Arnhem, 30 March 2021

Number: NTR NL-7827

DEKRA Certification B.V.

A handwritten signature in blue ink, appearing to read "H. Barends".

H.R.M. Barends  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

**CCA**  
**CENELEC CERTIFICATION AGREEMENT**  
**ACCORD DE CERTIFICATION DU CENELEC**

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
T +31 88 96 83000 F +31 88 96 83100 [www.dekra-certification.com](http://www.dekra-certification.com) Company registration 09085396

**CCA  
CENELEC CERTIFICATION AGREEMENT  
ACCORD DE CERTIFICATION DU CELENEC**

Ref. no. NTR NL 7827  
Page 1 of 1

Factory locations:

Wago Elwag sp.z.o.o.  
ul. Piekna 58 a  
50-506, Wroclaw  
Poland

Wago Elwag  
Innowacyjna 2  
55-330 Wroblowice  
Poland

Wago Pvt. Ltd.  
C-27, Sector-58, Phase III  
201301 Noida Uttar Pradesh  
India

Wago Electronic (Tianjin) Co. Ltd.  
No. 5 Quanhui Road  
Wu Qing Development Area  
301700 Tianjin  
China

WAGO Kontakttechnik GmbH & Co. KG  
Hansastraße 27, 32423 Minden/Westfalen  
Germany

WAGO Kontakttechnik GmbH & Co. KG, Werk Sondershausen  
Waldstrasse 1, 99706, Sondershausen  
Germany

WAGO Contact S.A.  
Route de l'Industrie 19, CP 168, 1564, Domdidier  
Switzerland

WAGO Kontakttechnik  
Cammer Str. 17,  
32423 Minden  
Germany





Test Report issued under the responsibility of:



<b>TEST REPORT</b> <b>IEC 60998-2-2:2004</b> <b>Connecting devices for low voltage circuits for household and similar purposes</b> <b>Part 2-2: Particular requirements for connecting devices as separate entities with</b> <b>screwless-type clamping units</b>	
Report Reference No.....	2245563.50
Date of issue.....	2021-02-24
Total number of page.....	41
Applicant's name.....	WAGO Kontakttechnik GmbH & Co. KG
Address.....	Hansastraße 27, 32423 Minden/Westfalen, Germany
<b>Test specification:</b>	
Standard.....	IEC 60998-2-2 (see also IEC 60 998-1:2002)
Test procedure.....	CB Scheme
Non-standard test method.....	N/A
<b>Test Report Form No.</b> ....	IEC60998_2_2B
Test Report Form(s) Originator.....	DEKRA certification B.V.
Master TRF.....	Dated 2012-02
<b>Copyright © 2011 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
<b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
Test item description.....	Splicing wire connector
Trade Mark.....	WAGO
Manufacturer.....	WAGO Kontakttechnik GmbH & Co. KG
Model/Type reference.....	Series 221
Ratings.....	450 V, 32 A, 4 mm <sup>2</sup>

<b>Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):</b>		
<input checked="" type="checkbox"/>	DEKRA Certification B.V.	DEKRA Certification B.V.
Testing location/ address.....:		Meander 1051, 6825 MJ Arnhem, The Netherlands
<input type="checkbox"/>	Associated CB Testing Laboratory:	
Testing location/ address.....:		
Tested by (name, function, signature).....:		A. A. P. Vught (Technician Industrial Safety) 
Approved by (name, function, signature)....:		F.S Strikwerda (Project Manager Industrial Safety) 
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address.....:		
Tested by (name, function, signature).....:		
Approved by (name, function, signature)....:		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address.....:		
Tested by (name + signature) .....		
Witnessed by (name, function, signature)..:		
Approved by (name, function, signature)....:		
<input checked="" type="checkbox"/>	Testing procedure: CTF Stage 3:	WAGO Kontakttechnik GmbH & Co. KG
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address.....:		Hansastraße 27, 32423 Minden/Westfalen, Germany
Tested by (name, function, signature).....:		J. Olbrich (Engineer) 
Witnessed by (name, function, signature)..:		H.L. Schendstok (Project Manager Industrial Safety) 
Approved by (name, function, signature)....:		R. Gioia (Team Leader) 
Supervised by (name, function, signature) :		F.S Strikwerda (Project Manager Industrial Safety) 

<p><b>List of Attachments (including a total number of pages in each attachment):</b></p> <p>Attachment A: EN 60998-1 CENELEC COMMON MODIFICATIONS and EN 60998-2-2 CENELEC COMMON MODIFICATIONS (2 pages) Attachment B: EN 60998-1 SPECIAL NATIONAL CONDITIONS, United Kingdom (1 page)</p>	
<p><b>Summary of testing:</b></p>	
<p><b>Tests performed (name of test and test clause):</b></p> <p><b>First Edition, 2168803.50:</b> Complete type-testing Tests are carried out on type 221-415 unless otherwise stated.</p> <p><b>Second Edition, 2221141.50:</b> This report replaces report 2168803.50 issued on 2014-02-12 Due to the fact of re-verification a temperature-rise test (clause 15) on 221-415 is carried out.</p> <p><b>Third Edition, 2224732.50:</b> This report replaces report 2221141.50 issued on 2017-10-19 Due to the fact that types 221-482, 221-483 and 221-485 are added. The following tests are carried out: clause 12.1, 12.2, 13.3, 13.4, 14.101, 14.2, 16.2, 16.3, 18, 19</p> <p><b>Fourth Edition, 2245563.50:</b> This report replaces report 2224732.50 issued on 2018-08-21, due to the fact that types 221-2401 and 221-2411 are added. The following tests are carried out under CTF3: clause 8, 9, 10, 10.104, 10.105, 10.106, 11, 12.1, 12.2, 13.3, 13.4, 14.101, 14.2, 15, 15.101, 16.2, 16.3, 17, 19</p> <p>The following test is carried out at DEKRA clause 18</p>	<p><b>Testing location:</b></p> <p><b>WAGO Kontakttechnik GmbH &amp; Co. KG Hansastraße 27, 32423 Minden/Westfalen, Germany</b></p> <p><b>WAGO Kontakttechnik GmbH &amp; Co. KG Hansastraße 27, 32423 Minden/Westfalen, Germany</b></p> <p><b>WAGO Kontakttechnik GmbH &amp; Co. KG Hansastraße 27, 32423 Minden/Westfalen, Germany</b></p> <p><b>WAGO Kontakttechnik GmbH &amp; Co. KG Hansastraße 27, 32423 Minden/Westfalen, Germany</b></p> <p><b>DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem The Netherlands</b></p>

**Summary of compliance with National Differences**

**List of countries addressed:**

European Group Differences

Special National Conditions United Kingdom

**The product fulfils the requirements of EN 60998-2-2: 2004 in conjunction with EN 60998-1:2004.**


**Copy of marking plate**


The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

Example for all types, except 221-2401 and 221-2411



**Example for type 221-2411**





**Test item particulars:**

- Number of terminals.....: single multiway
- Protection against electric shock.....: with without
- Means of fixing.....: with without
- Rated temperature.....: without T marking with T marking (85°C)
- IP number.....: IP-
- Type of terminals, screwless-type.....: universal non-universal push wire
- Conductor type.....: rigid flexible
- Rated connecting capacity.....:  0,14mm<sup>2</sup> "F"  0,2mm<sup>2</sup>  4mm<sup>2</sup>  1,5mm<sup>2</sup>  
 2,5mm<sup>2</sup>  4mm<sup>2</sup>  6mm<sup>2</sup>  10mm<sup>2</sup>
- Conductor insulation.....:  16mm<sup>2</sup>  25mm<sup>2</sup>  35 mm<sup>2</sup>
- Rated voltage (V ac / V dc ).....:  AC  DC

Classification of installation and use ..... :  
 Supply Connection ..... :



..... :
<b>Possible test case verdicts:</b> - test case does not apply to the test object .....: <b>N/A</b> - test object does meet the requirement.....: <b>P (Pass)</b> - test object does not meet the requirement .....: <b>F (Fail)</b>
<b>Testing</b> .....: Date of receipt of test item .....: <b>2019-11</b> Date (s) of performance of tests.....: <b>2021-01</b>
<b>General remarks:</b> The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.  Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.  N.B.: Projects performed under the IECCEB CB-Scheme CTF procedure, are fully in line with the procedures and requirements of the IECCEB CB-Scheme, but do not fall under DEKRA Netherland's laboratory accreditation, according to ISO/IEC 17025, by the Dutch Accreditation Council.

**Manufacturer's Declaration per sub-clause 6.2.5 of IEC 60947-2:**

The application for obtaining a CB Test Certificate  Yes  
 includes more than one factory location and a  Not applicable  
 declaration from the Manufacturer stating that the  
 sample(s) submitted for evaluation is (are)  
 representative of the products from each factory  
 has been provided .....

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies)..... :

**General product information:****Factory locations:**

**Wago Elwag sp.z.o.o.**  
 ul. Piekna 58 a  
 50-506, Wroclaw, Poland

**Wago Elwag**  
 Innowacyjna 2  
 55-330 Wroblowice, Poland

**Wago Pvt. Ltd.**  
 C-27, Sector-58, Phase III  
 201301 Noida Uttar Pradesh, India

**Wago Electronic (Tianjin) Co. Ltd.**  
 No. 5 Quanhui Road  
 Wu Qing Development Area  
 301700 Tianjin, China

**WAGO Kontakttechnik GmbH & Co. KG**  
 Hansastrasse 27, 32423 Minden/Westfalen  
 Germany

**WAGO Kontakttechnik GmbH & Co. KG, Werk Sondershausen**  
 Waldstrasse 1, 99706, Sondershausen  
 Germany

**WAGO Contact S.A.**  
 Route de l'Industrie 19, CP 168, 1564, Domdidier, Switzerland

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
<b>8</b>	<b>MARKING</b>		
8.1	On main part: <b>All types, except 221-2401 and 221-2411</b>		
	a) rated connecting capacity (mm <sup>2</sup> ) .....	<b>0,14 mm<sup>2</sup> "f"</b> <b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup></b>	<b>P</b>
	b) rated insulation voltage (V).....	<b>450 V</b>	<b>P</b>
	c) T marking (°C) (if > 40 °C or < -5 °C) .....	<b>85 °C</b> <b>catalogue</b>	<b>P</b>
	d) type reference .....	<b>221-415 example</b>	<b>P</b>
	e) manufacturer's or responsible vendor's name, trademark or identification mark .....	<b>WAGO</b>	<b>P</b>
	f) IP if > IP20 .....		<b>N</b>
	Small devices: only d) and e) indicated on device		<b>N</b>
	All marks visible on smallest package unit		<b>P</b>
8.1	On main part: <b>Types 221-2401 and 221-2411</b>		
	a) rated connecting capacity (mm <sup>2</sup> ) .....	<b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup></b>	<b>P</b>
	b) rated insulation voltage (V).....	<b>450 V</b>	<b>P</b>
	c) T marking (°C) (if > 40 °C or < -5 °C) .....	<b>85 °C</b> <b>catalogue</b>	<b>P</b>
	d) type reference .....	<b>221</b>	<b>P</b>
	e) manufacturer's or responsible vendor's name, trademark or identification mark .....	<b>WAGO</b>	<b>P</b>
	f) IP if > IP20 .....		<b>N</b>
	Small devices: only d) and e) indicated on device		<b>N</b>
	All marks visible on smallest package unit		<b>P</b>
8.101	Type of acceptable conductor "s" "r" or "f"		<b>P</b>
8.102	Marking indicating the length of insulation to be removed before insertion of the conductor		<b>P</b>
8.2	Multiway terminal devices: at least two adjacent		<b>N</b>
8.3	When symbols are used they shall be as follow: V for volts mm <sup>2</sup> or □ for square millimetres T for T-rating		<b>P</b>
8.4	Marking: durable and easily legible; 15 s water; 15 s hexane		<b>P</b>

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
<b>9</b>	<b>PROTECTION AGAINST ELECTRIC SHOCK</b>		
	Live parts not accessible		<b>P</b>
<b>10</b>	<b>CONNECTION OF CONDUCTORS</b>		
10.1	Connecting devices allow correct connection of conductors		<b>P</b>
10.101	Connection or disconnection: use a general tool or simple insertion	lever operated	<b>P</b>
	Disconnection operation other than a pull	lever operated	<b>P</b>
10.102	Terminals accept two or more conductors of same or different nominal cross-sectional areas; see table 101 (as specified by manufacturer):		<b>P</b>
	Universal terminals shall accept rigid(solid or stranded) and flexible unprepared conductors		<b>P</b>
	Non-universal terminals shall accept the types of conductors declared by the manufacturer		<b>P</b>
	Rated connecting capacity (mm <sup>2</sup> ) .....	<b>all types, except 221-2401 and 221-2411</b> <b>0,14 mm<sup>2</sup> "f"</b> <b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup></b>  <b>type 221-2401</b> <b>0,34 mm<sup>2</sup> - 4 mm<sup>2</sup></b>  <b>type 221-2411</b> <b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup></b>	<b>P</b>
	Suitable for connecting cross-sectional areas (mm <sup>2</sup> ) .....	<b>all types, except 221-2401 and 221-2411</b> <b>0,14 mm<sup>2</sup> "f"</b> <b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup> "f" "sol"</b> <b>1,5 mm<sup>2</sup> - 4 mm<sup>2</sup> "str"</b>  <b>type 221-2401</b> <b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup> "sol"</b> <b>0,34 mm<sup>2</sup> - 4 mm<sup>2</sup> "f"</b> <b>0,2 mm<sup>2</sup> - 2,5 mm<sup>2</sup> "str"</b>  <b>type 221-2411</b> <b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup> "f" "sol"</b> <b>0,2 mm<sup>2</sup> - 2,5 mm<sup>2</sup> "str"</b>	<b>P</b>
10.103	Terminals accept rigid and flexible conductors (table 101), unless otherwise specified (see 8.1)		<b>P</b>

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Smallest diameter (mm); largest diameter (mm).....:	<b>0,42 mm, 2,7 mm</b>	<b>P</b>
	During the test: terminals show no damage		<b>P</b>
10.104	Terminals clamp the conductor without undue damage: <b>All types, except 221-2401 and 221-2411</b>		
10.104.1	Connection/disconnection 5 times: smallest diameter (mm).....:	<b>0,14 mm<sup>2</sup> "f"</b>	<b>P</b>
	Connection/disconnection 5 times: largest diameter (mm).....:	<b>4 mm<sup>2</sup></b>	<b>P</b>
	After the test, terminal not damaged		<b>P</b>
10.104	Terminals clamp the conductor without undue damage: <b>Types 221-2411</b>		
10.104.1	Connection/disconnection 5 times: smallest diameter (mm).....:	<b>0,2 mm<sup>2</sup> solid and flexible</b>	<b>P</b>
	Connection/disconnection 5 times: largest diameter (mm).....:	<b>4 mm<sup>2</sup> solid, stranded and flexible</b>	<b>P</b>
	After the test, terminal not damaged		<b>P</b>
10.104.2	Rated cross-sectional area (mm <sup>2</sup> ) .....	<b>4 mm<sup>2</sup></b>	<b>P</b>
	Type .....	<b>rigid and flexible</b>	<b>P</b>
	After the test, no wire of conductor escaped outside the terminal		<b>P</b>
10.105	Secureness test:		
	during the test: the conductor does not slip out, no break near clamping unit and no damage	See appended table 10.105	<b>P</b>
10.106	Pull test:		
	- during the test the conductor does not come out	See appended table 10.106	<b>P</b>

<b>11</b>	<b>CONSTRUCTION</b>		
11.101	Contact pressure not transmitted via insulating material, unless there is sufficient resiliency		<b>P</b>
11.102	Insertion and disconnection, in accordance with manufacturer's instructions		<b>P</b>
	Openings clearly distinguishable		<b>P</b>
11.103	Terminals so constructed that:		
	- each conductor is clamped individually		<b>P</b>
	- conductors can be connected or disconnected at same time or separately	<b>separately</b>	<b>P</b>
	Possible to clamp maximum number of conductors	<b>1</b>	<b>P</b>



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
11.104	Inadequate insertion of conductor avoided		<b>P</b>
11.2	Clamping units clamp conductors reliably and between metal surfaces		<b>P</b>
11.3	Connecting devices: insulation of conductors not in contact with live parts of different polarity		<b>P</b>
11.4	Insulating lining: adequate mechanical strength and secured in a reliable manner		<b>P</b>
11.5	Current-carrying parts: adequate mechanical strength, electrical conductivity and resistance to corrosion; type of metal.....:	<b>tin plated copper</b>	<b>P</b>
	Current-carrying parts not made with electroplated coating if subjected to mechanical wear		<b>N</b>
11.6	Terminals: possible to connect number of conductors as specified by the manufacturer:		
	- number of conductors.....:	<b>1</b>	<b>P</b>
	- rigid, cross-sectional area (mm <sup>2</sup> ).....:	<b>0,2 mm<sup>2</sup> - 4 mm<sup>2</sup></b>	<b>P</b>
	- flexible, cross-sectional area (mm <sup>2</sup> ).....:	<b>all types, except 221-2401 and 221-2411 0,14 mm<sup>2</sup> - 4 mm<sup>2</sup> all types, except 221-2401 and 221-2411 0,2 mm<sup>2</sup> - 4 mm<sup>2</sup></b>	<b>P</b>
11.7	Fixing means of bases do not serve any other purpose		<b>P</b>
<b>12</b>	<b>RESISTANCE TO AGEING, TO HUMIDITY CONDITIONS, TO INGRESS OF SOLID OBJECTS AND TO HARMFUL INGRESS OF WATER</b> <b>Type 221-413, 221-482, 221-483, 221-485, 221-2411</b>		
12.1	Connecting devices resistant to ageing; after the test (168 h): no cracks visible, not sticky or greasy, no damage; test temperature (°C).....:	<input type="checkbox"/> 85 °C <input checked="" type="checkbox"/> <b>T + 30 °C=115 °C</b>	<b>P</b>
12.2	After humidity test (91-95%): no damage; test duration (168 h for connecting devices > IPx2, 48 h for all other).....:	<b>48 h</b>	<b>P</b>
12.3	IP test (IEC 60529).....:	IP__	<b>N</b>
	After the test, electric strength test as 13.4, and by inspection	IP__	<b>N</b>
	no appreciable entry of water		<b>N</b>
<b>13</b>	<b>INSULATION RESISTANCE AND ELECTRIC STRENGTH</b> <b>Type 221-415, 221-485, 221-2411</b>		

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
13.1	Insulated connecting devices provided with adequate insulation resistance and electric strength		<b>P</b>
13.2	Insulation between the connected conductors and the external surface is adequate for all the combinations of conductors		<b>P</b>
13.3	Insulation resistance measured 1 min after application of 500 V d.c.	See appended table 13.3	<b>P</b>
13.4	Electric strength test	See appended table 13.4	<b>P</b>
<b>14</b>	<b>MECHANICAL STRENGTH</b> <b>Type 221-415, 221-485, 221-2411</b>		
14.101	the test conductor, properly inserted into a clamping unit of the connection devices shall be allowed to be bent (deflected) in all 12 directions each of them differing from the adjacent directions by $30^\circ \pm 5^\circ$		
	Deflection test (principle of test apparatus shown in figure 103a):		
	- requirement: $\leq 2,5$ mV	See appended table 14.101	<b>P</b>
	max measured voltage drop (mV)	<b>0,99 mV</b>	<b>P</b>
14.2	Tumbling barrel (for < 50 g): 50 falls; after the test no damage	<b>4,15 g</b>	<b>P</b>
14.3	Impact test (for > 50 g): 10 blows:		
	- height of fall: 7,5 cm		<b>N</b>
	- height of fall: 10 cm		<b>N</b>
	- height of fall: 20 cm		<b>N</b>
	- height of fall: 25 cm		<b>N</b>
	After the test, no damage and live parts shall not become accessible		<b>N</b>
<b>15</b>	<b>TEMPERATURE RISE</b>		
	requirement: $\leq 45$ K		<b>P</b>
	max measured temperature rise (K)	See appended table 15	<b>P</b>
15.101	192 temperature cycles test, each cycle with a duration of 1 h, with the test current as defined in Table 2 of Part I		<b>P</b>
	Cabinet temperature (°C).....: <input type="checkbox"/> 40 <input checked="" type="checkbox"/> T-marking: <b>85 °C</b>		<b>P</b>
	Maximum voltage drop did not exceed 22,5 mV or 1,5 times 24 <sup>th</sup> cycle value	See appended table 15.101	<b>P</b>
<b>16</b>	<b>RESISTANCE TO HEAT</b>		
16.1	Connecting devices are sufficiently resistant to heat		<b>P</b>

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
16.2	Heating cabinet test	See appended table 16.2	<b>P</b>
	After the test: no changes impairing further use and markings still legible		<b>P</b>
16.3	Ball-pressure test (IEC 60695-10-2) for parts necessary to retain current-carrying parts and parts of the earthing circuit in position	See appended table 16.3A	<b>P</b>
	Impression diameter not exceed 2 mm		<b>P</b>
	Ball-pressure test (IEC 60695-10-2) for parts not necessary to retain current-carrying parts and parts of the earthing circuit in position	See appended table 16.3B	<b>N</b>
	Impression diameter not exceed 2 mm		<b>N</b>
<b>17</b>	<b>CLEARANCES AND CREEPAGE DISTANCES</b>		<b>P</b>
	Creepage distances, clearances and distances through sealing compound	See appended table 17	<b>P</b>
<b>18</b>	<b>RESISTANCE OF INSULATING MATERIAL TO ABNORMAL HEAT AND FIRE</b>		
	Glow-wire test (clauses 4 to 10 of IEC 60695-2-10)	See appended table 18	<b>P</b>
	No visible flames and no sustained glowing or flame and glowing extinguished within 30 s		<b>P</b>
	No ignition of the tissue paper or scorching of the board		<b>P</b>
<b>19</b>	<b>RESISTANCE OF INSULATING MATERIAL TO TRACKING</b>		
	Tracking test (IEC 60112): PTI 175 V, 50 drops, solution A	See appended table 19	<b>P</b>

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>10.105</b>						
<b>TABLE: Clamping securement and damage to the conductor test</b>						
Model/type reference.....:					<b>221-415</b>	
No of sample	Conductor cross-sectional area (mm <sup>2</sup> )	Conductor type	Mass for conductor (kg)	Height H (mm)	Diameter of bushing hole (mm)	
1-3	0,14	Flexible	0,1	260	6,4	P
4-6	0,2	Solid / flexible	0,1	260	6,4	P
7-9	4	Solid/ flexible	0,9	280	9,5	P
10-12	4	stranded	0,9	280	9,5	P
<b>Supplementary information:</b>						
<b>10.106</b>						
<b>TABLE: Pull-out test</b>						
Model/type reference.....:					<b>221-415</b>	
No of sample	Conductor cross-sectional area (mm <sup>2</sup> )	Conductor type	Pull force (N)			
1-3	0,14	flexible	10			P
4-6	0,2	solid / flexible	10			P
7-9	4	solid / flexible	60			P
10-12	4	stranded	60			P
<b>Supplementary information:</b>						

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>10.105</b>						
<b>TABLE: Clamping securement and damage to the conductor test</b>						
Model/type reference.....:					<b>221-2411</b>	
No of sample	Conductor cross-sectional area (mm <sup>2</sup> )	Conductor type	Mass for conductor (kg)	Height H (mm)	Diameter of bushing hole (mm)	
1-3	0,2	solid / flexible	0,2	260	6,4	P
4-6	4	solid / flexible	0,9	280	9,5	P
7-9	1,5	stranded	0,4	260	6,5	P
10-12	2,5	stranded	0,7	280	9,5	P
13-15	0,2	stranded	0,2	260	6,4	P
Supplementary information:						
<b>10.106</b>						
<b>TABLE: Pull-out test</b>						
Model/type reference.....:					<b>221-2411</b>	
No of sample	Conductor cross-sectional area (mm <sup>2</sup> )	Conductor type	Pull force (N)			
1-3	0,2	solid / flexible	10			P
4-6	4	solid / flexible	60			P
7-9	1,5	stranded	40			P
10-12	2,5	stranded	50			P
13-15	0,2	stranded	10			P
Supplementary information:						



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>10.105</b>						
<b>TABLE: Clamping securement and damage to the conductor test</b>						
Model/type reference.....:					221-2401	
No of sample	Conductor cross-sectional area (mm <sup>2</sup> )	Conductor type	Mass for conductor (kg)	Height H (mm)	Diameter of bushing hole (mm)	
1-3	0,2	solid	0,2	260	6,4	P
4-6	0,34	flexible	0,2	260	6,4	P
7-9	4	solid / flexible	0,9	280	9,5	P
13-15	2,5	stranded	0,7	280	9,5	P
16-18	0,2	stranded	0,2	260	6,4	P
Supplementary information:						
<b>10.106</b>						
<b>TABLE: Pull-out test</b>						
Model/type reference.....:					221-2401	
No of sample	Conductor cross-sectional area (mm <sup>2</sup> )	Conductor type		Pull force (N)		
1-3	0,2	solid		10		P
4-6	0,34	flexible		15		P
7-9	4	solid / flexible		60		P
13-15	2,5	stranded		50		P
16-18	0,2	stranded		10		P
Supplementary information:						

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>13.3</b>	<b>TABLE: Insulation resistance</b>		
	<b>Model/type reference.....:</b>	<b>221-415</b>	
	<b>Smallest cross-sectional area (mm<sup>2</sup>) :</b>	<b>0,14 mm<sup>2</sup> "f" / 0,2 mm<sup>2</sup> "r"</b>	
	<b>Largest cross-sectional area (mm<sup>2</sup>) :</b>	<b>4 mm<sup>2</sup> "r"</b>	
	<b>Test voltage applied between</b>	<b>Measured (MΩ)</b>	<b>Required (MΩ)</b>
	All clamping units together and the body	<b>&gt;20 MΩ</b>	<b>5 MΩ</b>
	Each clamping unit and all others together		
<b>Supplementary information:</b>			

<b>13.3</b>	<b>TABLE: Insulation resistance</b>		
	<b>Model/type reference.....:</b>	<b>221-485</b>	
	<b>Smallest cross-sectional area (mm<sup>2</sup>) :</b>	<b>0,14 mm<sup>2</sup> "f" / 0,2 mm<sup>2</sup> "r" / 0,2 mm<sup>2</sup> "f"</b>	
	<b>Largest cross-sectional area (mm<sup>2</sup>) :</b>	<b>4 mm<sup>2</sup> "r" / 4 mm<sup>2</sup> "f"</b>	
	<b>Test voltage applied between</b>	<b>Measured (MΩ)</b>	<b>Required (MΩ)</b>
	All clamping units together and the body	<b>&gt;20 MΩ</b>	<b>5 MΩ</b>
	Each clamping unit and all others together		
<b>Supplementary information:</b>			

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

13.3	TABLE: Insulation resistance		
	Model/type reference.....:	221-2411	
	Smallest cross-sectional area (mm <sup>2</sup> ) :	0,2 mm <sup>2</sup> solid and flexible	
	Largest cross-sectional area (mm <sup>2</sup> ) :	4 mm <sup>2</sup> solid, stranded and flexible	
	<b>Test voltage applied between</b>	<b>Measured (MΩ)</b>	<b>Required (MΩ)</b>
	All clamping units together and the body	>5 MΩ	5 MΩ
	Each clamping unit and all others together		
	<b>Supplementary information:</b>		

13.4	TABLE: Electric strength test		
	Model/type reference.....:	221-415	
	Rated insulation voltage (V).....:	450 V	
	<b>Test voltage applied between</b>	<b>Test voltage (V)</b>	<b>Flashover / breakdown (Yes/No)</b>
	All clamping units together and the body	2500 V	No
	Each clamping unit and all others together		
	<b>Supplementary information:</b>		

13.4	TABLE: Electric strength test		
	Model/type reference.....:	221-485	
	Rated insulation voltage (V).....:	450 V	
	<b>Test voltage applied between</b>	<b>Test voltage (V)</b>	<b>Flashover / breakdown (Yes/No)</b>
	All clamping units together and the body	2500 V	No
	Each clamping unit and all others together		
	<b>Supplementary information:</b>		

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>13.4</b>	<b>TABLE: Electric strength test</b>			
	Model/type reference.....:	<b>221-2411</b>		
	Rated insulation voltage (V).....:	<b>450 V</b>		
	<b>Test voltage applied between</b>	<b>Test voltage (V)</b>	<b>Flashover / breakdown (Yes/No)</b>	
	All clamping units together and the body	<b>2500 V</b>	<b>No</b>	
	Each clamping unit and all others together			
<b>Supplementary information:</b>				

<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-413</b>				
	0,1 times the test current (A) .....	<b>0,2 A</b>		<b>P</b>	
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>0,14 mm<sup>2</sup></b>		<b>P</b>	
	force (N) (table 104) .....	<b>0,09 N</b>		<b>P</b>	
	Distance (mm) (table 104) .....	<b>100 mm</b>		<b>P</b>	
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,39	0,38	0,39	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,39	0,38	0,38	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,39	0,38	0,38	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,38	0,39	0,38	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,38	0,39	0,38	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,39	0,39	0,38	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,38	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,39	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,39	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,38	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,38	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,39	0,39	0,39	<b>P</b>
	- requirement: ≤ 2,5 mV			<b>P</b>	

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

14.101	<b>TABLE: Mechanical strength Type 221-413</b>				
	0,1 times the test current (A) .....	<b>0,4 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>0,2 mm<sup>2</sup></b>			<b>P</b>
	force (N) (table 104) .....	<b>0,09 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,42	0,43	0,43	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,45	0,44	0,44	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,46	0,45	0,45	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,45	0,45	0,45	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,46	0,44	0,45	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,46	0,45	0,45	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,45	0,45	0,44	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,46	0,46	0,45	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,45	0,45	0,45	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,46	0,46	0,45	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,45	0,45	0,45	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,46	0,45	0,45	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>



IEC 60998-2-2					
Clause	Requirement + Test	Result - Remark			Verdict
<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-413</b>				
	0,1 times the test current (A) .....	<b>3,2 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>4 mm<sup>2</sup></b>			<b>P</b>
	force (N) (table 104) .....	<b>2 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,62	0,57	0,60	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,61	0,60	0,60	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,57	0,54	0,54	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,54	0,54	0,55	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,61	0,58	0,56	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,60	0,57	0,55	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,60	0,58	0,59	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,61	0,60	0,59	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,61	0,60	0,60	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,59	0,58	0,58	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,59	0,58	0,59	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,58	0,58	0,58	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2					
Clause	Requirement + Test	Result - Remark			Verdict
<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-485</b>				
	0,1 times the test current (A) .....	<b>0,2 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>0,14 mm<sup>2</sup> flexible</b>			<b>P</b>
	force (N) (table 104) .....	<b>0,09 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,38	0,38	0,39	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,38	0,38	0,38	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,38	0,38	0,38	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,37	0,39	0,38	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,37	0,39	0,37	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,37	0,39	0,37	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,37	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,37	0,39	0,37	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,39	0,39	0,37	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,37	0,39	0,39	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,38	0,39	0,37	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,37	0,39	0,39	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-485</b>				
	0,1 times the test current (A) .....	<b>0,4 A</b>	<b>P</b>		
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>0,2 mm<sup>2</sup> solid</b>	<b>P</b>		
	force (N) (table 104) .....	<b>0,09 N</b>	<b>P</b>		
	Distance (mm) (table 104) .....	<b>100 mm</b>	<b>P</b>		
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,41	0,43	0,43	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,44	0,44	0,45	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,45	0,44	0,45	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,45	0,45	0,41	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,46	0,44	0,41	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,45	0,46	0,42	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,45	0,45	0,42	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,46	0,46	0,43	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,45	0,45	0,41	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,44	0,46	0,45	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,45	0,47	0,43	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,44	0,45	0,45	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2					
Clause	Requirement + Test	Result - Remark			Verdict
<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-485</b>				
	0,1 times the test current (A) .....	<b>3,2 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>4 mm<sup>2</sup> solid</b>			<b>P</b>
	force (N) (table 104) .....	<b>2 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,62	0,57	0,60	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,61	0,60	0,60	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,59	0,54	0,54	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,56	0,54	0,55	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,62	0,58	0,56	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,61	0,57	0,55	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,63	0,58	0,59	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,61	0,60	0,59	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,61	0,60	0,60	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,55	0,58	0,58	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,56	0,58	0,59	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,57	0,58	0,58	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2					
Clause	Requirement + Test	Result - Remark			Verdict
<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-485</b>				
	0,1 times the test current (A) .....	<b>3,2 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>4 mm<sup>2</sup> stranded</b>			<b>P</b>
	force (N) (table 104) .....	<b>2 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,68	0,66	0,65	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,68	0,72	0,71	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,69	0,65	0,65	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,64	0,74	0,73	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,66	0,73	0,73	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,68	0,64	0,67	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,69	0,66	0,69	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,64	0,62	0,68	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,71	0,75	0,73	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,72	0,74	0,71	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,72	0,73	0,72	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,73	0,75	0,74	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2					
Clause	Requirement + Test	Result - Remark			Verdict
<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-42411</b>				
	0,1 times the test current (A) .....	<b>0,4 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>0,2 mm<sup>2</sup> solid</b>			<b>P</b>
	force (N) (table 104) .....	<b>0,09 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,56	0,55	0,55	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,56	0,55	0,55	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,56	0,56	0,56	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,55	0,56	0,55	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,56	0,56	0,56	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,58	0,58	0,56	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,57	0,56	0,56	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,57	0,56	0,56	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,58	0,57	0,56	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,57	0,56	0,56	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,57	0,56	0,56	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,56	0,56	0,56	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2					
Clause	Requirement + Test	Result - Remark			Verdict
<b>14.101</b>	<b>TABLE: Mechanical strength Type 221-42411</b>				
	0,1 times the test current (A) .....	<b>3,2 A</b>			<b>P</b>
	smallest cross-sectional area (mm <sup>2</sup> ) 10.103 .....	<b>4 mm<sup>2</sup> solid</b>			<b>P</b>
	force (N) (table 104) .....	<b>2 N</b>			<b>P</b>
	Distance (mm) (table 104) .....	<b>100 mm</b>			<b>P</b>
	-screwless terminal number	1	2	3	-
	- voltage drop measured (mV) (1 <sup>st</sup> deflection) .....	0,99	0,84	0,89	<b>P</b>
	- voltage drop measured (mV) (2 <sup>nd</sup> deflection) .....	0,96	0,91	0,93	<b>P</b>
	- voltage drop measured (mV) (3 <sup>rd</sup> deflection) .....	0,78	0,94	0,74	<b>P</b>
	- voltage drop measured (mV) (4 <sup>th</sup> deflection) .....	0,65	0,71	0,63	<b>P</b>
	- voltage drop measured (mV) (5 <sup>th</sup> deflection) .....	0,50	0,51	0,52	<b>P</b>
	- voltage drop measured (mV) (6 <sup>th</sup> deflection) .....	0,47	0,53	0,58	<b>P</b>
	- voltage drop measured (mV) (7 <sup>th</sup> deflection) .....	0,51	0,51	0,51	<b>P</b>
	- voltage drop measured (mV) (8 <sup>th</sup> deflection) .....	0,47	0,44	0,48	<b>P</b>
	- voltage drop measured (mV) (9 <sup>th</sup> deflection) .....	0,48	0,51	0,63	<b>P</b>
	- voltage drop measured (mV) (10 <sup>th</sup> deflection) .....	0,55	0,55	0,60	<b>P</b>
	- voltage drop measured (mV) (11 <sup>th</sup> deflection) .....	0,51	0,58	0,67	<b>P</b>
	- voltage drop measured (mV) (12 <sup>th</sup> deflection) .....	0,81	0,82	0,92	<b>P</b>
	- requirement: ≤ 2,5 mV				<b>P</b>

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>15</b>	<b>TABLE: Temperature rise</b>		
	Model/type reference.....	<b>221-415</b>	
	Terminal .....	<input checked="" type="checkbox"/> <b>single</b> <input type="checkbox"/> <b>multiway</b>	—
	T marking (°C) .....	<input checked="" type="checkbox"/> <b>Yes (85°C):</b>	—
	Largest cross-sectional area (mm <sup>2</sup> ).....	<b>4 mm<sup>2</sup></b>	
	Conductors .....	<b>rigid and flexible</b>	
	Rated connecting capacity (mm <sup>2</sup> ).....	<b>4 mm<sup>2</sup></b>	
	Test current (A).....	<b>32 A</b>	
<b>Thermocouple Locations</b>		<b>max. temperature measured, (K)</b>	<b>max. temperature limit, (K)</b>
On conductor in the terminal T1		<b>21</b>	<b>45</b>
On conductor in the terminal T2		<b>22</b>	<b>45</b>
On conductor in the terminal T3		<b>21</b>	<b>45</b>
On conductor in the terminal T4		<b>22</b>	<b>45</b>
On conductor in the terminal T5		<b>22</b>	<b>45</b>
	Model/type reference.....	<b>221-415</b>	
	Terminal .....	<input checked="" type="checkbox"/> <b>single</b> <input type="checkbox"/> <b>multiway</b>	—
	T marking (°C) .....	<input checked="" type="checkbox"/> <b>Yes (85°C):</b>	—
	Used cross-sectional area (mm <sup>2</sup> ) .....	<b>4 mm<sup>2</sup></b>	
	Conductors .....	<b>rigid</b>	
	Test current (A).....	<b>32 A</b>	
<b>Thermocouple Locations</b>		<b>max. temperature measured, (K)</b>	<b>max. temperature limit, (K)</b>
On conductor in the terminal T1		<b>24</b>	<b>45</b>
On conductor in the terminal T2		<b>23</b>	<b>45</b>
On conductor in the terminal T3		<b>22</b>	<b>45</b>
On conductor in the terminal T4		<b>23</b>	<b>45</b>
On conductor in the terminal T5		<b>24</b>	<b>45</b>
Supplementary information:			



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>15</b>	<b>TABLE: Temperature rise</b>		
	Model/type reference.....	<b>221-2411</b>	
	Terminal .....	<input checked="" type="checkbox"/> <b>single</b> <input type="checkbox"/> <b>multiway</b>	—
	T marking (°C) .....	<input checked="" type="checkbox"/> <b>Yes (85°C):</b>	—
	Largest cross-sectional area (mm <sup>2</sup> ).....	<b>4 mm<sup>2</sup></b>	
	Conductors .....	<b>solid, stranded and flexible</b>	
	Rated connecting capacity (mm <sup>2</sup> ).....	<b>4 mm<sup>2</sup></b>	
	Test current (A).....	<b>32 A</b>	
	<b>Thermocouple Locations</b>	<b>max. temperature measured, (K)</b>	<b>max. temperature limit, (K)</b>
	On conductor in the terminal and wire (sample with solid wire)	<b>27 26 26</b>	<b>45</b>
	On conductor in the terminal and wire (sample with flexible wire)	<b>24 28 25</b>	<b>45</b>
	On conductor in the terminal and wire (sample with stranded wire)	<b>19 20 19</b>	<b>45</b>
Supplementary information:			

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

15.101	<b>TABLE: Temperature-cycling test</b>			
	Model/type reference .....	<b>221-415</b>		
	Smallest cross-sectional area (mm <sup>2</sup> ) .....	<b>0,14 mm<sup>2</sup> flexible</b>		
	Test current (Table 2) (A).....	<b>2 A</b>		
Measured voltage drop of:		Measured voltage drop (mV)		
		Sample 1	Sample 2	Sample 3
Solid conductors	(after 24 cycles)			
Stranded conductors	(after 24 cycles)			
Flexible conductors	(after 24 cycles)	<b>1,31</b>	<b>1,40</b>	<b>1,36</b>
Solid conductors	(1,5 times 24 <sup>th</sup> cycle value)			
Stranded conductors	(1,5 times 24 <sup>th</sup> cycle value)			
Flexible conductors	(1,5 times 24 <sup>th</sup> cycle value)	<b>1,96</b>	<b>2,10</b>	<b>2,04</b>
Solid conductors	(after 192 cycles)			
Stranded conductors	(after 192 cycles)			
Flexible conductors	(after 192 cycles)	<b>0,89</b>	<b>1,01</b>	<b>0,99</b>
	Largest cross-sectional area (mm <sup>2</sup> ) .....	<b>4 mm<sup>2</sup> rigid flexible</b>		
	Test current (Table 2) (A).....	<b>32 A</b>		
Measured voltage drop of:		Measured voltage drop (mV)		
		Sample 1	Sample 2	Sample 3
Solid conductors	(after 24 cycles)	<b>2,31</b>	<b>2,10</b>	<b>2,00</b>
Stranded conductors	(after 24 cycles)	<b>2,12</b>	<b>2,23</b>	<b>2,10</b>
Flexible conductors	(after 24 cycles)	<b>2,00</b>	<b>2,50</b>	<b>2,64</b>
Solid conductors	(1,5 times 24 <sup>th</sup> cycle value)	<b>3,46</b>	<b>3,15</b>	<b>3,00</b>
Stranded conductors	(1,5 times 24 <sup>th</sup> cycle value)	<b>3,18</b>	<b>3,34</b>	<b>3,15</b>
Flexible conductors	(1,5 times 24 <sup>th</sup> cycle value)	<b>3,00</b>	<b>3,75</b>	<b>3,96</b>
Solid conductors	(after 192 cycles)	<b>1,85</b>	<b>1,83</b>	<b>1,87</b>
Stranded conductors	(after 192 cycles)	<b>1,79</b>	<b>1,81</b>	<b>1,80</b>
Flexible conductors	(after 192 cycles)	<b>2,00</b>	<b>2,50</b>	<b>2,64</b>
Supplementary information:				

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

15.101	TABLE: Temperature-cycling test				
	Model/type reference .....	221-415			
	Smallest cross-sectional area (mm <sup>2</sup> ) .....	0,2 mm <sup>2</sup> rigid flexible			
	Test current (Table 2) (A).....	4 A			
	Measured voltage drop of:	Measured voltage drop (mV)			
		Sample 1	Sample 2	Sample 3	
	Solid conductors (after 24 cycles)	1,72	1,54	1,71	P
	Stranded conductors (after 24 cycles)				
	Flexible conductors (after 24 cycles)	1,79	1,79	2,10	P
	Solid conductors (1,5 times 24 <sup>th</sup> cycle value)	2,58	2,31	2,56	P
	Stranded conductors (1,5 times 24 <sup>th</sup> cycle value)				
	Flexible conductors (1,5 times 24 <sup>th</sup> cycle value)	2,68	2,68	3,15	P
	Solid conductors (after 192 cycles)	1,48	1,27	1,26	P
	Stranded conductors (after 192 cycles)				
	Flexible conductors (after 192 cycles)	1,28	1,14	1,89	P

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

15.101	TABLE: Temperature-cycling test				
	Model/type reference .....	221-2411			
	Smallest cross-sectional area (mm <sup>2</sup> ) .....	0,2 mm <sup>2</sup> solid and flexible			
	Test current (Table 2) (A).....	4 A			
	Measured voltage drop of:	Measured voltage drop (mV)			
		Sample 1	Sample 2	Sample 3	
	Solid conductors (after 24 cycles)	10,18	11,90	12,14	
	Stranded conductors (after 24 cycles)				
	Flexible conductors (after 24 cycles)	11,10	15,04	13,51	P
	Solid conductors (1,5 times 24 <sup>th</sup> cycle value)	15,27	17,85	18,21	
	Stranded conductors (1,5 times 24 <sup>th</sup> cycle value)				
	Flexible conductors (1,5 times 24 <sup>th</sup> cycle value)	16,65	22,56	20,27	P
	Solid conductors (after 192 cycles)	10,03	11,46	11,80	
	Stranded conductors (after 192 cycles)				
	Flexible conductors (after 192 cycles)	11,35	15,24	13,47	P
	Largest cross-sectional area (mm <sup>2</sup> ) .....	4 mm <sup>2</sup> solid, stranded and flexible			
	Test current (Table 2) (A).....	32 A			
	Measured voltage drop of:	Measured voltage drop (mV)			
		Sample 1	Sample 2	Sample 3	
	Solid conductors (after 24 cycles)	15,33	12,71	13,91	P
	Stranded conductors (after 24 cycles)	13,36	14,49	10,92	P
	Flexible conductors (after 24 cycles)	13,41	16,01	16,31	P
	Solid conductors (1,5 times 24 <sup>th</sup> cycle value)	23,00	19,07	20,87	P
	Stranded conductors (1,5 times 24 <sup>th</sup> cycle value)	20,04	21,74	16,38	P
	Flexible conductors (1,5 times 24 <sup>th</sup> cycle value)	20,12	24,02	24,47	P
	Solid conductors (after 192 cycles)	15,28	12,44	13,83	P
	Stranded conductors (after 192 cycles)	13,26	14,71	13,00	P
	Flexible conductors (after 192 cycles)	13,68	16,55	16,33	P
Supplementary information:					

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

16.2	TABLE: Heating cabinet test			
	Test temperature (°C).....:	<input type="checkbox"/> 85°C <input checked="" type="checkbox"/> T + 45 = 130 °C		
	Model/type reference	Sample 1	Sample 2	Sample 3
	<b>221-413</b>	<b>P</b>	<b>P</b>	<b>P</b>
	<b>221-485</b>	<b>P</b>	<b>P</b>	<b>P</b>
	<b>221-2411</b>	<b>P</b>	<b>P</b>	<b>P</b>
Supplementary information:				

16.3A	TABLE: Ball pressure test of insulating materials all types, except 221-2401 and 221-2411			
	Test temperature (°C).....:	<input type="checkbox"/> 125 <input checked="" type="checkbox"/> T + 45 =130 °C		
	Part under test	Material designation / manufacturer	Impression diameter (mm)	
	<b>Housing</b>	Xantar	<b>1 mm</b>	<b>P</b>
	<b>Lever orange</b>	Celanex	<b>1 mm</b>	<b>P</b>
	<b>Lever orange</b>	Ultradur	<b>1 mm</b>	<b>P</b>
	<b>Lever grey</b>	Polyamide for Zytel	<b>0,8 mm</b>	<b>P</b>
Supplementary information:				

16.3A	TABLE: Ball pressure test of insulating materials types 221-2401 and 221-2411			
	Test temperature (°C).....:	<input type="checkbox"/> 125 <input checked="" type="checkbox"/> T + 45 =130 °C		
	Part under test	Material designation / manufacturer	Impression diameter (mm)	
	<b>Housing</b>	Xantar	<b>0,99 mm</b>	<b>P</b>
	<b>Lever orange</b>	Celanex	<b>0,85 mm</b>	<b>P</b>
	<b>Cover</b>	Makrolon	<b>1,01 mm</b>	<b>P</b>
Supplementary information:				

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>16.3B</b>	<b>TABLE: Ball pressure test of insulating materials</b>			
	Test temperature (°C).....:	<input type="checkbox"/> 70	<input type="checkbox"/> T + 40 =	
	Part under test	Material designation / manufacturer	Impression diameter (mm)	<b>N</b>
Supplementary information:				

<b>17</b>	<b>TABLE: Clearances and creepage distances all types, except 221-2401 and 221-2411</b>				
	Rated insulation voltage (V).....:	450 V			<b>P</b>
	Clearance cl, creepage distance cr and distance through sealing compound tsc at/of:	Required cl, cr, tsc (mm)	Measured cl (mm)	Measured cr (mm)	Measured tsc (mm)
	<b>Between clamping units</b>				
	<b>Clamping units - surface</b>	<b>4</b>	<b>4,05</b>	<b>4,07</b>	<b>-</b>
Supplementary information:					

<b>17</b>	<b>TABLE: Clearances and creepage distances types 221-2401 and 221-2411</b>				
	Rated insulation voltage (V).....:	450 V			<b>P</b>
	Clearance cl, creepage distance cr and distance through sealing compound tsc at/of:	Required cl, cr, tsc (mm)	Measured cl (mm)	Measured cr (mm)	Measured tsc (mm)
	<b>Between clamping units</b>				
	<b>Clamping units - surface</b>	<b>4</b>	<b>4,11</b>	<b>4,11</b>	<b>-</b>
Supplementary information:					

IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

18	TABLE: Glow-wire test		
Part under test	Material designation / manufacturer	Test temperature (°C)	Time of extinguish of flames and glowing, if any
<b>housing and lever (type 221-415)</b>	Xantar / Celanex / Ultradur	<b>850°C</b>	flame extinguished immediately after removal.
<b>housing and lever (type 221-485)</b>	Xantar / Polyamide for Zytel	<b>850°C</b>	flame extinguished immediately after removal.
Supplementary information:			

18	TABLE: Glow-wire test		
Part under test	Material designation / manufacturer	Test temperature (°C)	Time of extinguish of flames and glowing, if any
<b>housing and lever (type 221-2401)</b>	Xantar (transparent) / Celanex (orange)	<b>850°C</b>	flame extinguished immediately after removal.
Supplementary information:			

19	TABLE: Tracking		
Part under test	Material designation / manufacturer	Test voltage (V)	Remarks
<b>housing</b>	Xantar	<b>175 V</b>	<b>P</b>
<b>Lever orange</b>	Celanex	<b>175 V</b>	<b>P</b>
<b>Lever orange</b>	Ultradur	<b>175 V</b>	<b>P</b>
<b>Lever grey</b>	Polyamide for Zytel	<b>175 V</b>	<b>P</b>
<b>Cover</b>	Makrolon	<b>175 v</b>	<b>P</b>
Supplementary information:			


Remarks

---


**Illustrations:**



Type: 221-412



Type: 221-413



Type: 221-415



Type: 221-482



Type: 221-483




Type: 221-485




Remarks

---



Type 221-2401



Type 221-2411

Annex A IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

**ATTACHMENT TO TEST REPORT IEC 60998-2-2  
EUROPEAN GROUP DIFFERENCES AND NATIONAL DIFFERENCES**

**Connecting devices for low voltage circuits for household and similar purposes  
Part 2-2: Particular requirements for connecting devices as separate entities with  
screwless-type clamping units**

**Differences according to** .....: EN 60998-1 : 2004 and EN 60998-2-2 : 2004 in conjunction with  
IEC 60998-1 : 2002 and IEC 60998-2-2 : 2002

**Attachment Form No.** ....: [EU\\_GD\\_IEC60998\\_2\\_2B](#)

**Attachment Originator**.....: DEKRA certification B.V.

**Master Attachment** .....: [Date \(2013-02\)](#)

**Copyright © 2008 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.**

EN 60998-1 CENELEC COMMON MODIFICATIONS			
<b>1</b>	<b>Scope</b>		
delete	In the first paragraph ", and equivalent AWG conductors".		<b>P</b>
<b>6.2</b>	<b>Main characteristics</b>		
delete	NOTE 1		<b>P</b>
<b>8.3</b>	<b>Marking</b>		
delete	the NOTE		<b>P</b>
<b>11.6</b>	<b>Construction</b>		
delete	", or equivalent AWG conductors".		<b>P</b>
<b>15.4</b>	<b>Temperature rise</b>		
delete	the NOTE		<b>P</b>
<b>Annex</b>	<b>B</b>		
delete	The whole annex		<b>P</b>

Annex A IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>EN 60998-2-2</b>			
<b>CENELEC COMMON MODIFICATIONS</b>			
<b>10.103</b>	<b>Connection of conductors</b>		
delete	NOTE 1		<b>P</b>
delete	In Table 101, NOTE 2, "and for AWG conductors, on ASTM B172-71, ICEA publication S-19-81, ICEA Publication S-66-524 and ICEA Publication S-65-516."		
<b>10.105</b>			
delete	NOTE 1 and NOTE 2		<b>P</b>
<b>10.106</b>			
delete	NOTE 1 and NOTE 2		<b>P</b>
<b>14.101</b>	<b>Mechanical strength</b>		
delete	the NOTE		<b>P</b>
<b>Annex</b>	<b>BB</b>		
delete	The whole annex		<b>P</b>

Annex B IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

<b>ANNEX ZB</b> <b>(normative)</b> <b>SPECIAL NATIONAL CONDITIONS</b> <b>(EN 60998-1)</b>			
<b>Special national condition: National characteristic or practice that cannot be changed even over a long period, e.g. climatic conditions, electrical earthing conditions.</b>			
<b>NOTE If it affects harmonization, it forms part of the European Standard.</b>			
<b>For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.</b>			
Clause			
<b>6.2</b>	<b>United Kingdom</b>		
Replace	The entire subclause by:  6.2 The standard rated connecting capacities are 0,2 mm <sup>2</sup> , 0,34 mm <sup>2</sup> , 0,5 mm <sup>2</sup> , 0,75 mm <sup>2</sup> , 1 mm <sup>2</sup> , 1,25mm <sup>2</sup> , 1,5 mm <sup>2</sup> , 2,5 mm <sup>2</sup> , 4 mm <sup>2</sup> , 6 mm <sup>2</sup> , 10 mm <sup>2</sup> , 16 mm <sup>2</sup> , 25 mm <sup>2</sup> , and 35 mm <sup>2</sup>		<b>P</b>







OD ECS 040-1  
January 2019

Responsible CB



### TEST REPORT SUMMARY

Report Number.....	2245563.50
Date of issue.....	2021-02-24
Tested by (name, function, signature):	J. Olbrich (Engineer) 
Witnessed by (name, function, signature):	H.L. Schendstok (Project Manager Industrial Safety) 
Approved by (name, function, signature):	R. Gioia (Team leader) 
Supervised by (name, function, signature):	F.S. Strikwerda (Project Manager Industrial Safety) 

Testing Laboratory.....	DEKRA Certification B.V.
Address .....	Meander 1051, 6825 MJ Arnhem, The Netherlands
Testing procedure.....	<input type="checkbox"/> ENEC <input checked="" type="checkbox"/> CCA NTR <input type="checkbox"/> ENEC based on IECIE CBTC with number: .....
Customer Testing Procedure.....	<input type="checkbox"/> TMP/CTF Stage 1 <input type="checkbox"/> WMT/CTF Stage 2 <input checked="" type="checkbox"/> SMT/CTF Stage 3

Applicant.....	WAGO Kontakttechnik GmbH & Co. KG
Address .....	Hansastraße 27, 32423 Minden/Westfalen, Germany
Manufacturer.....	WAGO Kontakttechnik GmbH & Co. KG
Address .....	Hansastraße 27, 32423 Minden/Westfalen, Germany

Product.....	Splicing wire connector
Model/Type reference .....	Series 221
Trademark.....	
Ratings .....	450 V, 32 A, 4 mm <sup>2</sup>

Certification Scheme .....	<input type="checkbox"/> ENEC <input checked="" type="checkbox"/> CCA <input type="checkbox"/> Other: _____
Standard(s).....	EN 60998-2-2: 2004 in conjunction with EN 60998-1:2004
<input checked="" type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC is equivalent with the corresponding IEC Publication.	
<input checked="" type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC with agreed common modifications and is <u>not</u> equivalent with the corresponding IEC Publication. An EU Deviation Addendum has to be issued.	

**This EN test report consists of the following parts:**

<input checked="" type="checkbox"/> IEC Test Report Number.....	2245563.50
<input checked="" type="checkbox"/> EU Deviation Addendum.....	2245563.50 Attachment A

Copyright © 2019, ETICS Brussels, Belgium. All rights reserved.  
 This ECS document together with the test report is only valid if signed by an approved ENEC or CCA Testing Laboratory and accompanied by the associated ENEC Licence or CCA Notification of Test Results, issued by a Certification Body member of ECS.